

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

**The Principal
Brahmrishi Bawra Shanti Vidya Peeth
Senior Secondary School (10+2)
Dina Nagar, Dhar Road
Udhampur**

No: DFES-FP/9/2022-04(CC-7079422) 985

Dated: 08.06.2023

Sub: Fire Safety Certificate.

Ref: Your online application submission dated: 26.04.2023 (FI-326499).

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed 13 Nos. of Hose Reel Hoses and 15 Nos. of First Aid Fire Extinguishers in their school premises. Besides this, two underground water storage tanks of 75 KL & 15 KL capacity are also available. The school is about 05 Km away from Fire and Emergency Station Udhampur and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity each should be provided near each main electric switch board panel in addition to already existing fire extinguisher.
2. At least two dedicated persons working in your school be earmarked as Fireman who can maintain fire fighting system and its operation in case of emergency round the clock. However, on your personal request, any assistance in terms of training of your employees if required for handling/operating the fixed/first aid fire fighting equipments installed in your school. The nearest fire & emergency station can be approached for the same.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. Fixed/First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
5. All electric installations existing in the building should be concealed conduit type.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
9. Out of three triple storey blocks, one block having only one staircase. As such, one additional emergency exit/staircase should be provided in this block for safe and quick evacuation of students/staff in case of any emergency.
10. The management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
11. At present school is having four blocks, three are triple storey and one is four storey. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
12. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
13. This clearance shall be subject to outcome of any dispute/investigation/enquiry/ trial if any, pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued.
14. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school building. However, before granting permission/recognition/ extension or renewal thereof , the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018. Issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.

Jay Kumar
Director

**Fire & Emergency Services, J&K
Jammu/Srinagar**